

**About use of Beghelli ordinary lighting fixtures for emergency lighting applications with S230 (Sicuro system) with particular reference to LED Panel DALI(code 42313)**

The IEC EN 60598-2-22 products' requirements for emergency lighting applications, which define their performance, construction, safety, etc., are fulfilled by Beghelli Fixed Led Luminaires provided with electronic controlgear.

Beghelli ordinary lighting luminaires (including 42313) are designed in compliance with all IEC EN 60598-2-22 requirements except from the marking and labelling which has to be respected for the application as emergency luminaires.


Provided that the marking and labelling reports the due indications as stated in EN60598-2-22 the Beghelli's luminaires are suitable for emergency lighting installations according to EN1838 and other European national installation rules.

At your disposal for any clarification

Best regards.

*Valsamoggia; April 23, 2024*

**BEGHELLI SpA**  
Eng. Gianni Borelli  
Technical Scientific Director



**GRUPPO BEGHELLI**

LDVV24D26